

ADDENDUM NUMBER 3
City of Avon Park
Avon Park Control Panel Modifications
Bid Number 20-05
November 24, 2020

1. From the non-mandatory site visit on November 23rd at the Bell Water Treatment Plant where the proposed SCADA modifications were discussed, the City requests SCADA software mentioned below to be included in the bid. This is in addition to the labor required to perform the SCADA modifications to provide the City the ability to control the water treatment plant equipment remotely via SCADA.

SCADA Software and Objective

(1) VTScada 1k tag limit – Runtime – New - Includes three months of supportplus.

(1) VTScada 1k tag limit – Alarm Notification – New - Includes three months of supportplus.

(1) VTScada 1k tag limit – Thin Client – 5 Pack – New - Includes three months of supportplus.

(1) Supportplus – Additional Nine Months.

(1) New onsite at WTP Server to house VTScada
Server to include: 1 ng3000-hd workstation O.S. Windows 10 Pro
Intel NUC NUC1015FNK case
Intel i5 4 core cpu
Additional NIC for local network
16 gig ddr5 ram
512 gig SS hard drive x2
20" HCMi LED Monitor
USB keyboard and mouse

Objective: provide a small dustless robust workstation for harsh conditions such as shop area hi humidity environment. Uptime 24/7 on unit with remote access for admins and users.